

Summary Report for Municipalities – 2025



Peterborough Water Treatment Plant

Municipal Drinking Water Licence: 145-101, Issue No. 7

Municipal Waterworks No: 220000497

Capability of Water System

The annual summary of water delivered in 2025 is as follows:

Month	Average Day (M³/d)	Maximum Day (M³/d)	Peak Flows (L/m)
January	26,975	28,956	20,108
February	26,919	30,132	20,925
March	26,009	30,709	21,326
April	25,888	28,166	19,560
May	27,287	30,247	21,005
June	31,788	46,310	32,160
July	35,144	38,627	26,824
August	33,148	37,675	26,163
September	29,308	33,211	23,063
October	27,039	30,052	20,869
November	26,569	30,495	21,177
December	25,800	31,010	21,535

The Municipal Drinking Water Licence rates the plant at a daily maximum of 104,000 M³; therefore, there were no exceedances of this Licence. The Permit to Take Water allows a maximum raw water taking of 190.68 ML/day, therefore there were no exceedances of this permit. The Permit to Take Water also stipulates a maximum allowable limit of 132,743 L/m, again there were no exceedances.

Submission of this Report

Schedule 22, section 22-2(1) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report to be submitted to the City of Peterborough as the Owner of the Drinking Water System.

Period Covered by this Report

Schedule 22, section 22-2(5) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report to cover the period of January 1, 2025, to December 31, 2025.

Failure to Meet Requirements of the Safe Drinking Water Act and Regulations

There are no known failures to meet the requirements of the Safe Drinking Water Act, 2002 or any current regulation made under this Act.

Failure to Meet Requirements of the Municipal Drinking Water Licence

There are currently no known failures to meet the requirements of the terms and conditions of Municipal Drinking Water Licence, number 145-101, Issue No.7.

Failure to Meet Requirements of Provincial Officer Orders

There were no Provincial Officer's Orders issued during the period covered by this report. Any previously issued orders have been addressed. There are currently no known failures to meet the requirements of the terms and conditions of any Provincial Officer's Orders.

Water Supplied to Others

The Township of Selwyn's Woodland Acres development receives all of its drinking water from the Peterborough municipal water system. A copy of this report has been provided to the Township of Selwyn as required by Schedule 22, section 22-2(4) of O. Reg. 170/03 under the Safe Drinking Water Act.

This report has been prepared by Patricia Skopelianos, Program Manager, Quality Assurance as representative of the Owner.

