



City of
Peterborough

TO: Members of Arenas, Parks and Recreation Advisory Committee

FROM: Sue Warrington, Arena Division Manager

MEETING DATE: June 18, 2013

SUBJECT: Report APRAC13-022
Arena Lighting Levels – Evinrude Centre and Kinsmen Arena

PURPOSE

An interim report to respond to the Arenas, Parks and Recreation Advisory Committee on the issue of lighting levels over the ice pads at the Evinrude Centre and Kinsmen Arena.

RECOMMENDATION

That the Arenas, Parks and Recreation Advisory Committee approve the recommendation outlined in Report APRAC13-022, dated June 18, 2013, of the Arena Division Manager, as follows:

That the report be received for information.

BUDGET AND FINANCIAL IMPLICATIONS

There is no budget or financial implication resulting from the approval of the recommendation of Report APRAC13-022.

BACKGROUND

The project to replace the arena pad lighting to an energy efficient model at the Evinrude Centre and Kinsmen Arena was undertaken in 2013. The end result of the conversion has resulted in lower lighting levels in some areas of the ice pads at both facilities.

Staff are currently working with the engineer on this project to correct the situation. A follow up report will be presented when the project is complete.

Submitted by,

Sue Warrington
Arena Division Manager

Contact Name: Sue Warrington
Phone: 705-742-7777 Ext. 2504
Toll Free: 1-855-738-3755
Fax: 705-743-2196
E-Mail: swarrington@peterborough.ca